




THIRD STORY LIGHTING-PROPOSED



SCALE: 1/8" = 1'-0"

GENERAL NOTES:
CONNECT ALL DEVICES TO NEW POWER PANEL NPA.

- KEYED NOTES:**
- 1 EXISTING TO REMAIN
 - 2 EMERGENCY EXIT LIGHT COMBO UNIT (READUPLITE: SM-CX3000 SERIES, SM329MH12)
 - 3 REMOVE ALL EXISTING LIGHTING FIXTURES AND DEVICES ON THIS FLOOR, EXCEPT STAIR CASE AND H/C LIFT.
 - 4 CONFIRM ALL FIXTURE TYPE WITH ARCH.
 - 5 VERIFY LOCATION OF LIGHT WITH ARCH. READ IN CONJUNCTION TO OFFICE (VERIFY LOCATION)
 - 6 CEDAR CEILING PANEL C/W INDIRECT FLUORESCENT FIXTURE ABOVE (VERIFY LOCATION).
 - 7 EMERGENCY EXIT LIGHT COMBO UNIT (READUPLITE: SM228M12-CX5100L12U)

LUMINAIRE SCHEDULE

TYPE	DESCRIPTION	LAMPS	MOUNTING	REMARKS
A	HID LIGHT FIXTURE - KEENE: LPM2C102MAL1 OR EQUAL	100W MH HID	WALL	
B	HID BOLLARD LIGHT FIXTURE - BEGA: 8482MH OR EQUAL	50W MH HID	BOLLARD	
C	SURFACE MOUNTED LIGHT FIXTURE (STAIR) - BEGA: 2579P OR EQUAL	2-26W PL	SURFACE	
D	FLUORESCENT LIGHT FIXTURE - CFI: 044WA23212050 OR EQUAL	2-32W T8	SURFACE	
E	POT LIGHT FIXTURE IN CORRIDOR - LIGHTOLIER: 2001FBU/2001WH OR EQUAL	18W TTT	RECESSED	
F	FLUORESCENT LIGHT FIXTURE - CFI: BELMONT GLOD 10306-12050 OR EQUAL	2-32W T8	SURFACE	
G	AERIAL HANGER UP/DOWN FLUORESCENT LIGHT FIXTURE - LIGHTOLIER: EYP435FX232-12050 OR EQUAL	2-32W T8	AERIAL HANGER	
H	SURFACE MOUNTED LIGHT FIXTURE IN WASHER AND DRYER ROOM - BEGA: 2579P OR EQUAL	26W PL	SURFACE	
J	POLE / COLUMN MOUNTED COMPACT FLUORESCENT LIGHT FIXTURE - EQUIPSE: U-1-XL1-D-TT1(2) 42-120-EB (PAINTED SAND BLACK) OR EQUAL	2-42W TTT	POLE OR COLUMN MOUNTED	
K	FLUORESCENT LIGHT FIXTURE RECESSED WITHIN THE STRUCTURAL TEE - CFI: DP52132LS43212050-FK92X4 OR EQUAL	4-32W T8	RECESSED	
L	POT LIGHT FIXTURE IN SUITE - LIGHTOLIER: LYTECASTER 2002P1/2045 OR EQUAL	40W A19	RECESSED	
M	WALL MOUNTED BATHROOM MIRROR LIGHT FIXTURE IN SUITE - THOMAS: S-1702-41 OR EQUAL	2-40W A19	WALL	
N	SURFACE MOUNTED LIGHT FIXTURE IN SUITE - THOMAS: S18452-90 OR EQUAL	2-60W A19	SURFACE	
P	INDIRECT LIGHTING ABOVE CEDAR CEILING PANEL - WILLIAMS: 79A-4-232-F-EB2-120 OR EQUAL	2-32W T8	CABLE W/D	
Q	4' FLUORESCENT STRIP LIGHT FIXTURE - CFI: TASKMASTER II TCU32M-12050 OR EQUAL	1-32W T8	SURFACE	
Q1	3' FLUORESCENT STRIP LIGHT FIXTURE - CFI: TASKMASTER II TCU25M-12050 OR EQUAL	1-25W T8	SURFACE	
Q2	2' FLUORESCENT STRIP LIGHT FIXTURE - CFI: TASKMASTER II TCU17M-12050 OR EQUAL	1-17W T8	SURFACE	
R	COMPACT FLUORESCENT LIGHT FIXTURE (SHOWER) - LIGHTOLIER: LYTECASTER 1021/1001T3U120 OR EQUAL	13W 01/TTT	SURFACE	
S	POT LIGHT FIXTURE IN ENTRY LOBBY - LIGHTOLIER: 2001FBU/2001WH OR EQUAL	18W TTT	RECESSED	

AMU: Architects

PROJECT: UNIT 201A/201B
ADDRESS: 2019 DUNDAS ST. W. VANCOUVER, BC V6J 1M5
TEL: 604.677.7880
FAX: 604.677.7880
EMAIL: AMU@TELUS.NET

designer: PC date: MAY 2008
drawn by: SK scale: AS SHOWN
checked: PC project no.: 08-6158-E15
digital file no.:

Project Name:
AMC TRANSITION HOUSING
2019 DUNDAS ST.
VANCOUVER, B. C.

Drawing Title:
PROPOSED-THIRD-STORY LIGHTING-PLAN

Drawing No: **E2** Revision No: **07**



Cobalt Engineering
Suite 305 - 425 Howe Street
Vancouver, BC V6C 2E7
Tel: 604.687.1807
Fax: 604.687.1807
E-Mail: info@cobalt-engineering.com
Project Reference: 14030-01-54-415

date	description	by	signature
01	19 MAY 08	ISSUED FOR REVIEW	PC
02	13 MAY 08	ISSUED FOR PERMITS	PC
03	25 MAY 08	ISSUED FOR PERMITS	PC
04	08 JUL 08	ISSUED FOR BUILDING PERMITS	PC
05	02 FEB 09	ISSUED FOR PERMITS	PC
06	18 FEB 09	ISSUED FOR PERMITS	PC
07	04 MAR 09	RE-ISSUED FOR PERMITS	PC